

A D D E N D U M N O. 1

August 25, 2022

PROJECT: REPLACEMENT OF WATER METER ENDPOINTS

Village of Cold Spring, Putnam County, New York

Contractors bidding the referenced project are advised of the following information and revisions to the Bid Documents.

QUESTIONS AND ANSWERS

- Q1. Per page 330901-03, Part 3 Execution 3.1 C: “Each company shall have at least one plumber on the installation team that is licensed to work in Putnam County, NY. Other workers may be apprentice plumbers.” The work being performed is not plumbing work but rather electronic upgrades. This requirement is redundant since per our recent experience in Putnam County, meters being replaced in kind do not require a Plumbers license. Techs do not have to operate valves or replace meters or perform any moderate “plumbing” work but rather wire work.
- A. The worker performing the endpoint replacement does not have to be a Putnam County licensed plumber but must have a minimum of five years’ experience performing similar work. The worker shall not perform any plumbing type work.